

PSU & UPS Compatibility Test Report

Test Equipment

Oscilloscope - Kenwood CS-5270

Power Supply - SST- OP700

UPS - Centralion model 600VA 800VA 1000VA 2000VA

Test Condition

AC Input Voltage - 240V / 50Hz

Temp. - Room Temp.

Loading - No Load


Power Supply OFF - 5Vsb Mode

Centralion Test Result

Centralion UPS output waveform measure by using Oscilloscope and Bulk Cap.


Voltage measure by using Multi-Meter

Model: 600VA




PSU Bulk Cap. Voltage 408V

Model: 800VA




PSU Bulk Cap. Voltage 470V

Model: 1000VA



PSU Bulk Cap. Voltage 497V

Model: 2000VA



PSU Bulk Cap. Voltage 435V

PSU & UPS Compatibility Test Report

Test Equipment

Oscilloscope - Kenwood CS-5270

Power Supply - SST- OP700

UPS - APC model 650 & 1000

Test Condition

AC Input Voltage - 240V / 50Hz

Temp. - Room Temp.

Loading - No Load


Power Supply OFF - 5Vsb Mode

APC Test Result

APC UPS output waveform measure by using Oscilloscope and Bulk Cap.


Voltage measure by using Multi-Meter

Model: 650 old version




PSU Bulk Cap. Voltage 475V

Model: 650 new version



PSU Bulk Cap. Voltage 437V

Model: 1000 (True Sine Wave output)



PSU Bulk Cap. Voltage 329V